

Request for Proposal (RFP)
Bid No: 22-05-2798LE
Addendum No. 2

Date: June 16, 2022

To: All Proposers

Subject: Addendum No. 2
Consisting of 2 pages

RFP No.: Bid 22-05-2798LE

Project Name: N35(8)1,2&4 Road Improvement Project in Sweetwater, AZ

Owner: Navajo Division of Transportation

Proposer shall acknowledge the receipt of this Addendum No. 2 on Form 1442 and make note of and/or incorporate all changes listed below into the requested Request for Proposal (RFP):

REVISIONS TO THE CONTRACT DOCUMENTS INCLUDED IN THIS AMENDMENT:

I. PROJECT PLANS

DWG D24, Sheet 51 of 66, Standard Fencing Details: is revised as follows: Barbed wire shall be galvanized wire or aluminum coated wire conforming to AASHTO M 280. Line posts shall conform to the requirements of ASTM A702. The type of post furnished, tee, channel, U or Y type, shall be the same on the project.

End, corner, latch, and gate posts and braces shall conform to the requirements of ASTM A702, for uprights and braces.

Posts shall be painted green.

I. QUESTIONS AND ANSWERS subsequent to the Pre-Proposal Meeting held May 25, 2022 and Addendum No. 1.

Q14: Plan Sheet 51 (Fencing Detail), General Note No. 1 calls for galvanized line, end and corner posts. All fencing materials, painted and galvanized, have been in extremely short supply, but galvanized has been especially difficult to get pricing on. Would NDOT be willing to accept painted line, end and corner posts in lieu of the galvanized? Many suppliers will not even quote the galvanized because they have no idea as to when they might become available.

A14: NDOT has changed the material specification for the N35 project. Please note the changes as addressed in Addendum 2.

Request for Proposal (RFP)
Bid No: 22-05-2798LE
Addendum No. 2

END OF ADDENDUM NO. 2

Thank you for your interest!

 6/16/22

Ardaniel Begay, Principal Contract Analyst
Project Contact Person