

Addendum # 3

Upper Moenkopi Well

IHS Project PH 15-U77 / EA 02-20

1. **ITEM:** There are 2 items on the Bid Form related to the proposed 6" water main's connection to the existing MUA water main.

RESOLUTION: Contractor shall do the following:

- a) Include a bid price on both Bid Items # 3 and #4 items on the Bid FORM spreadsheet found in Item 3.1 in the Project Manual.
- b) Include both costs in the sub-total amount near the bottom of the Bid Form

After the award of the contract, the owner will choose which method that the Contractor will be required to use. Payment to the contractor will only be for the bid item for the actual method installed at its associated bid price on the Bid Form.

The total bid (including both options) will be the base for selecting the contractor.

- 2) The existing MUA water line to which the new proposed 6" line will be tied into is a 6" PVC line. Exact PVC material type is unknown.