



TO ALL HOLDERS OF CONTRACT DOCUMENTS FOR:

**The Navajo Nation
Tohatchi East Flats Individual Wells
Bid Number 21-12-2686LE**

ADDENDUM NO. 5

March 2, 2022

This Addendum shall be incorporated into the Contract Documents for the above referenced project.

Item No. 1 – Navajo Nation Tax on Bid Form

Per page 3 of C-410, do not include Navajo Nation Tax in the total of base bid or alternate.

Item No. 2 – Submittal of Bid

Please refer to Article 15 of C-200 for requirements.

Item No. 3 – Pressure Switch Range

Pressure switch range shall be 30 psi low/50 psi high.

Item No. 4 – Square D LC1D12 Coil Voltage

For 3HP motor LC1D18U7 (230V, single phase, 3HP) with 240V coil.

Item No. 5 – Franklin Pumptec Plus protection systems, Correction to Part Number

Pumpteck-Plus 5800060100 (230V, 60Hz, 0.5-5.0HP)

This Addendum constitutes clarifications, changes, additions, modifications and/or deletions to the Contract Documents. All provisions of the Contract Documents not affected by this Addendum shall remain in full force. This Addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original Contract Documents and previous Addenda, if any. Receipt of this Addendum shall be acknowledged on the Bid Form.



Colin Daly, P.E.

3/2/2022
Date