

**ADDENDUM No. 2
TO
CONTRACT DOCUMENTS FOR CONSTRUCTION OF
THE TSE'II'AHÍ WATER LINE EXTENSIONS PROJECT**

THE NAVAJO NATION

May 10, 2024

This is ADDENDUM No. 2 to the CONTRACT DOCUMENTS FOR CONSTRUCTION OF THE TSE'II'AHÍ WATER LINE EXTENSIONS PROJECT, bid package published April 2024. This ADDENDUM No. 2 consists of two (2) pages. All interested bidders are hereby notified of the following clarifications, changes, additions, modifications and deletions to the Contract Documents, as described in detail below:

Item 1. Clarifications in Response to Submitted Questions

The following additional clarifications are made in response to questions from potential bidders.

1. Sheet DT-24, rear and front elevations: The only metal building components to the booster station building exterior are the doors and louvered vents. The Vents are detailed on the plan view of booster station.
2. Technical Specification 33 11 00 Part 2.1. "Ductile iron pipe" Part B.2.d "Buried service (site piping only, excluding chlorination building): Bituminous coating, per AWWA C151". This includes the ductile iron pipe in the pressure sustaining valve vault shown on Sheet DT-15.
3. Refer to Specification 31 23 17 Part 3.3.E for allowable open trench requirements.
4. The intent of the as-built survey is to provide actual placement of work as described in Technical Specification Section 01 00 00 Part 1.3.LL and Part 1.51. It is the responsibility of the Contractor to adhere to the as-built survey requirements, including the actual placement of pipelines and appurtenances as described in the referenced Technical Specification Section.

Item 2. Electronic files available to bidders

The following files (in .pdf file format) referenced and requested have been made available to Bidders through the Engineer's website at www.soudermiller.com . Bidder's requiring further assistance in obtaining these files should contact Royce Beaudry at royce.beaudry@soudermiller.com or 707-363-8161.

The following files **are** part of the Bid / Contract Documents:


- Addendum No. 1
 - Including Revised Bid Form (*Replaced the original version included in Volume 1 of bid documents*)
- Addendum No. 2

The following files **are not** part of the Bid / Contract Documents, and are not intended to modify, update or interpret the Bid / Contract Documents in any way:

- Prebid meeting notes (*also includes*):

- Pre-Bid Meeting Notes & Sign-in Sheet.
- Excerpt from basic requirements.
- Project overview map.

This Addendum No. 2 constitutes clarification, changes, additions, modifications and deletions to the aforementioned contract documents. All provisions of the contract documents not in conflict with Addendum No. 2 shall remain in full force. This Addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original Contract Documents and previous Addenda, if any. Receipt of this Addendum shall be acknowledged on the Bid Form.



Royce Beaudry, P.E.

May 10, 2024

Date