



**Navajo Nation**  
**Through Its Department of Water Resources Water Management Branch**  
**February 25, 2025**

**TO:** All Interested Bidders

**FROM:** Brown and Caldwell

**SUBJECT:       ADDENDUM #1 NOTICE**

Let this memorandum serve as a notice of additional information regarding the **“Cameron Booster Pump Station and Pressure Reducing Valves Project Navajo Nation Bid Number 24-09-3468LE”**.

Below are questions collected from firms interested in this invitation for bid with responses as follows:

1. Is the omission of “HVAC” in Bid Schedules C & D intentional?

The size of the pumps for booster pump station No. 1 requires air conditioning for the building. Booster Pump Stations 2 and 3 have tiny pumps that will not require air conditioning. These two buildings are precast buildings as shown in IHS Detail W-9. This detail shows louvered vents that should be included in the cost of the precast building Item No. C4 and D4. These buildings will require a heater. This heater is called out as keynote No. 14 on sheet E-111 and E-121 for both pump stations. Include this heater in Item No. C6 and D6 on the bid form.